


- A. ALL FITTINGS TO BE RESTRAINED.
- B. CHIMNEY SEALS MUST BE INSTALLED.
- C. PRECAST MANHOLE RISER SECTION 5'-0" DIAMETER MIN. ASTM C478. NOTE ACTUAL SIZE TO BE DESIGNED WITH SIZE OF FORCEMAIN AND EACH INDIVIDUAL SITUATION.
- D. IN WET AREAS SEAL BOTTOM WITH POURED CONCRETE BASE OR PRECAST MANHOLE BASE.
- E. LOCATION OF THESE ARE AT THE DISCRETION



SEWAGE COMBINATION AIR VALVE IN MANHOLE

FORCE MAIN PRESSURE CLEANOUT

CITY OF URBANA

SEWAGE COMBINATION AIR VALVE CHAMBER

REVISIONS:

DATE APPROVED: 01-13-06 PAGE No.

1167.95