



**NOTES**

- A.** ALL WORK TO CONFORM TO ODOT CONSTRUCTION AND MATERIAL SPECIFICATIONS LATEST REVISION UNLESS OTHERWISE SPECIFIED.
- B.** ITEM 407 TACK COAT, SHALL BE REQUIRED WHEN 10 DAYS HAVE ELAPSED BETWEEN BITUMINOUS PAVEMENT LIFTS UNLESS OTHERWISE SPECIFIED BY THE ENGINEER. APPLICATION RATE IS 0.08 GALLON PER SQUARE YARD.
- C.** ALL BUTT JOINTS SHALL BE SEALED WITH PG 64-22 WITHIN 24 HOURS AFTER PLACEMENT OF ITEM 448.
- D.** STANDARD DIMENSIONS FOR (II) B\B CURB AND (IV) CURB LAWN WIDTH ASSUME PARKING ON BOTH SIDES.
- E.** SIDEWALK OF 4' WIDTH MAY BE APPROVED BY THE CITY ON ARTERIAL, INDUSTRIAL AND COMMERCIAL.
- F.** IN AREAS WITH HIGH POTENTIAL OF PUSHING, SHOVING OR HEAVING, USE ITEM 448 ASPHALT CONCRETE SURFACE COURSE TYPE 1H, PG. 70-22. IN SMALL QUANTITY AREAS USE TYPE 1, PG 64-22 WITH GILSONITE ADDITIVE.
- G.** ALL NEW STREETS ARE TO BE CONSTRUCTED USING ASPHALT. CONCRETE PAVEMENT WILL NOT BE ACCEPTED.
- H.** ITEM 408 PRIME COAT SHALL BE APPLIED ON ITEM 304 AGGREGATE BASE AT THE RATE OF 0.4 GAL/SY PRIOR TO ASPHALT.

MINIMUM STANDARDS						
	ITEM	DESCRIPTION	THOROUGHFARE	COMM., IND. & RES. COLLECTOR	RESIDENTIAL THROUGH STREET	LOCAL
STANDARD DIMENSIONS	I	RIGHT-OF-WAY	*	61'	60'	50'
	II	B\B CURB	*	41'	37'	33'
	III	SIDEWALK WIDTH	*	5'	4'	4'
	IV	CURB LAWN WIDTH	*	4'	7'	4'
AGGREGATE BASE	V	ITEM 448	1-1/2" MIN	1-1/2" MIN	1-1/2" MIN	1-1/2" MIN
	VI	ITEM 448	1-1/2"	1-1/2"	1-1/2"	1-1/2"
	VII	ITEM 301	6"	5"	4"	3"
	VIII	ITEM 304	9" 2 LIFTS	9" 2 LIFTS	9" 2 LIFTS	9" 2 LIFTS
ASPHALT BASE	V	ITEM 448	1-1/2" MIN	1-1/2" MIN	1-1/2" MIN	1-1/2" MIN
	VI	ITEM 448	1-1/2"	1-1/2"	1-1/2"	1-1/2"
	VII	ITEM 301	8" 2 LIFTS	7" 2 LIFTS	6"	5"
	VIII	ITEM 304	4"	4"	4"	4"

\* SEE DESIGN CRITERIA AND CITY ENGINEER  
A 10' EASEMENT IS TO BE PLACED ALONG THE RIGHT-OF-WAY LINE.