

## **Phoenix Drive Reconstruction Addendum #2**

**To: All Bidders**

**From: Michael L. Heintz, City Engineer**

**Date: August 2, 2012**

**Re: Intermediate Asphalt Binder Type/Change in Bid Date**

### **Intermediate Asphalt Binder Type**

On Page 17 (Section I) of the Bid Documents and Page 3 (Section IV) of the separate Specifications/Plans, locations that read 'Item 448 Asphalt Concrete, Intermediate, Type 2, PG64-22' shall be replaced with 'Item 448 Asphalt Concrete, Intermediate, Type 2, PG64-28' as shown under the Typical Section, Page 3 of the Specifications/Plans. A revised bid form (Page 17) shall be included as part of this addendum to reflect this change.

### **Change in Bid Date**

Due to the late issuance of this addendum, the bid opening for this project shall be delayed one week until Monday, August 13, 2012 at 10:00AM. Any references to the bid opening date in the advertisement for bids and bid documents shall be revised to reflect this change. The bid opening time shall remain 10:00AM. Only the bid opening date shall be changed.

Bidder acknowledges receipt of the following addendum:

---

The unit prices on the Specific Master Sheet Proposal below for the Phoenix Drive Reconstruction shall include all bonds, insurance, labor, permits, licensing, and necessary equipment and tools to complete the project and to cover the finished work of the several kinds called for:

## CITY OF URBANA

### Phoenix Drive Reconstruction

#### Master Sheet Proposal (Base Bid)

ITEM NO.	DESCRIPTION	UNIT OF MEASURE	APPROX. QUANTITY (a)	UNIT COST (b)	TOTAL COST (a x b)
202	REMOVED, AS PER PLAN	LUMP	1	_____	_____
204	SUBGRADE COMPACTION	S.Y.	967	_____	_____
253	PAVEMENT PLANING, ASPHALT CONCRETE	S.Y.	133	_____	_____
301	ASPHALT BASE	C.Y.	720	_____	_____
320	RUBBLIZATION	S.Y.	6,774	_____	_____
407	TACK COAT @ 0.04 GAL/SY	GAL	442	_____	_____
411	STABILIZED CRUSHED AGGREGATE, DRIVES & BERMS	C.Y.	249	_____	_____
448	ASPHALT CONCRETE, SURFACE, TYPE 1H, PG76-22M	C.Y.	231	_____	_____
448	ASPHALT CONCRETE, INTERM, TYPE 2, PG64-28	C.Y.	217	_____	_____
452	8" NON-REINFORCED CONCRETE	S.Y.	967	_____	_____
614	MAINTAINING TRAFFIC	LUMP	1	_____	_____
SPEC	MISCELLANEOUS, AS PER PLAN	LUMP	1	_____	_____
<b>GRAND TOTAL</b>				_____	_____

The bidder agrees that this bid shall be good and may not be withdrawn for a period of sixty (60) calendar days after the scheduled closing time for receiving bids.

Upon receipt of written notice of the acceptance of this bid, bidder will execute the formal contract attached within ten (10) days and deliver a Surety Bond or Bonds as required by the General Conditions. The bid security attached in the sum of \_\_\_\_\_ (\$ \_\_\_\_\_) is to become the property of the Owner in the event the contract and bond are not executed within the time above set forth, as liquidated damages for the delay and additional expense to the Owner caused thereby.

Respectfully submitted:

BY \_\_\_\_\_  
(Signature)

(SEAL - if bid by a corporation)

\_\_\_\_\_  
(Title)

\_\_\_\_\_  
(Business Name)