

NOTES

- A.** FOR 4" AND GREATER SERVICES.
- B.** PIPING SHALL BE D.I.P. CLASS 53 TO RIGID FLANGE. FROM RIGID FLANGE THROUGH METER VALVES AND BYPASS TO BE DUCTILE, COPPER OR BRASS.
- C.** FOR 1-1/2" AND 2" SERVICES: WATER DEPARTMENT RECOMMENDS THE USE OF COPPER PIPING.
- D.** FULL PORT GATE OR BALL VALVES IN LIEU OF VALVES MAY BE INSTALLED FOR 1-1/2" AND 2", METERS MUST BE LOCKABLE.
- E.** BYPASS MANDATORY FOR ALL METERS 1" AND LARGER. BYPASS VALVE TO BE LOCKABLE.
- F.** INSTALLATION FOR DUAL BACKFLOW PREVENTION DEVICES IS OPTIONAL FOR 1-1/2" -2" METERS.
- G.** ALTERNATE DESIGNS MAY BE SUBMITTED TO UTILITY DIRECTOR FOR APPROVAL.
- H.** PROVIDE SPREADER DEVICE FOR PROPER ALIGNMENT ON INSTALLATION OF METER SPREAD.
- I.** NO FLANGE ADAPTERS BEFORE INITIAL SHUT-OFF VALVE(S).

**METER SPREAD
(FACE TO FACE)**

1 1/2"	13"	FLANGED
2" COMPOUND	15"	FLANGED
2" SINGLE	17"	FLANGED
3" COMPOUND	17"	FLANGED
4"	20"	FLANGED
6"	24"	FLANGED
8" AND LARGER TO BE REVIEWED BY THE CITY		

