



SERVICE TEES ARE PERMITTED IF

- A.** SHOWN ON AN APPROVED SET OF CONSTRUCTION PLANS.
- B.** 4" MINIMUM BRANCH AND SERVICE LINE WITH GATE VALVE WITHIN 3' OF MAIN.
- C.** ALL TEE'S MUST BE PRE-APPROVED BY WATER SUPERINTENDENT.

NOTE

- A.** METER SHALL BE LOCATED INSIDE THE BUILDING.
- B.** EACH LINE SHALL HAVE SEPARATE METER AND TURN OFF.

**CITY OF
URBANA**

**4" AND LARGER WATER MAIN SERVICE
CONNECTION (DOMESTIC)**

REVISIONS:

DATE
APPROVED:
01-13-06
PAGE No.

1167.62