



NOTE:

A. ALL BACKFLOW PREVENTION ASSEMBLIES SHALL BE DELIVERED FOR INSTALLATION COMPLETELY ASSEMBLED BY THE ORIGINAL MANUFACTURER WITH ALL COMPONENTS AS APPROVED.

B. CLASS 53 DUCTILE IRON TO VALVE. ALL JOINTS RESTRAINED.

**CITY OF
URBANA**

**DOUBLE DETECTOR
CHECK VALVE ASSEMBLY DETAIL**

REVISIONS:

DATE
APPROVED:
01-13-06
PAGE No.

1167.65